

Bid RFI 02
Roof Sent via Email
December 27, 2016

Will the entire TPO roof be replaced? Leaving existing POLY ISO insulation?

- *Replace entire TPO roof with new.*
- *Leave existing POLY ISO insulation.*
- *Add new insulation at existing openings being closed up to match adjacent thickness.*

