

ADDENDUM NO. 6
TO THE
DRAWINGS AND PROJECT MANUAL
FOR
**CLIFTON ELEMENTARY SCHOOL AND
NEW PERFORMING ARTS CENTER
CLIFTON INDEPENDENT SCHOOL DISTRICT
CLIFTON, TEXAS**



06/27/2017

VLK ARCHITECTS, INC.
2821 West 7th Street, Suite 300
Fort Worth, TX 76107
817.633.1600 voice
817.633.9600 fax
vlkarchitects.com

6.1 GENERAL

- A. This addendum modifies the drawings and project manual, dated March 6, 2017, as noted within and shall become part of the Contract Documents.
- B. Proposers shall acknowledge receipt of this addendum in the space provided on the proposal form. Failure to do so may subject proposer to disqualification.
- C. Each holder of proposal documents registered with the Construction Manager will receive a copy of the addendum. Each prime proposer is responsible for distribution of information conveyed by this addendum to its sub-proposers and suppliers.

6.2 PROPOSAL REQUEST NO. 1 - CLIFTON ELEMENTARY SCHOOL

- A. SECTION 27 10 00 – STRUCTURED CABLING SYSTEM
 - 1. Page 27 10 10 - 10, Sub-Paragraph 2.3, C, 2, c, 1; Change part number to “DP245E88TGY” in lieu of “CPPL24WBLY”.
 - 2. Page 27 10 10 - 10, Sub paragraph 2.3, C, 2, c, 2. Change part number to “DP485E88TGY” in lieu of “CPPL48WBLY”.

6.3 PROPOSAL REQUEST NO. 2 - NEW PERFORMING ARTS CENTER

- A. SECTION 27 10 00 – STRUCTURED CABLING SYSTEM
 - 1. Page 27 10 10 - 10, Sub-Paragraph 2.3, C, 2, c, 1; Change part number to “DP245E88TGY” in lieu of “CPPL24WBLY”.
 - 2. Page 27 10 10 - 10, Sub paragraph 2.3, C, 2, c, 2. Change part number to “DP485E88TGY” in lieu of “CPPL48WBLY”.

CLIFTON ELEMENTARY SCHOOL

6.4 SHEET E3.03 – FLOOR PLAN – UNIT ‘C’ – POWER

- A. At MDF C124, provide (1) quadplex power receptacle that is connected to panelboard ‘CRB’ with a 20 amp breaker for the PA system.

6.5 SHEET E7.01 - SCHEDULES

- A. At MDF C124, provide (1) quadplex power receptacle that is connected to panelboard 'CRB' with a 20 amp breaker for the PA system.

END OF ADDENDUM NO. 6