



MORE THAN ARCHITECTS

ADDENDUM

NO. 1

TO THE DRAWINGS AND THE PROJECT MANUAL

PROJECT NAME: Field House Renovation for Lorena High School

CLIENT NAME: Lorena ISD

LOCATION: Lorena, Texas

PROJECT NUMBER: 1676-04-03

PROPOSAL DATE: Tuesday, October 18, 2016, 2:00PM

ADDENDUM DATE: Thursday, October 13, 2016

For additional information regarding this project, contact Aaron Mynar at aaron@mazaneconstruction.com or 254-799-0291.



10-13-16

THIS ADDENDUM INCLUDES:

Structural Items	0 Pages
Architectural Items	1 Pages
Plumbing Items	0 Pages
Mechanical Items	0 Pages
Electrical Items	0 Pages
Technology Items	1 Pages

AND ALL ATTACHED REVISED DRAWING REFERENCES IN THE ADDENDUM

Huckabee

AUSTIN • DALLAS • FORT WORTH • HOUSTON • WACO
www.huckabee-inc.com



10-13-16

ARCHITECTURAL ITEMS FOR ADDENDUM NO. 1

NOTICE TO PROPOSERS:

- A. This Addendum shall be considered part of the contract documents for the above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original contract documents, this Addendum shall govern and take precedence.
- B. Proposers are hereby notified that they shall make any necessary adjustments in their estimate on account of this Addendum. It will be construed that each Proposer's proposal is submitted with full knowledge of all modifications and supplemental data specified therein. Acknowledge receipt of this addendum in the space provided on the proposal form. Failure to do so may subject Proposer to disqualification.

REFERENCE IS MADE TO THE DRAWINGS AND THE PROJECT MANUAL AS NOTED:

PROJECT MANUAL:

AD No 1, Arch. Item 1: To the Project Manual, Section 00 2116-1, "INSTRUCTIONS TO PROPOSERS";

Refer to Paragraph A under 1.01 SEALED PROPOSALS. The address to deliver sealed proposals should read "1508 New Dallas Highway, Waco, Texas 76705.

AD No 1, Arch. Item 2: To the Project Manual, Section 08 7100, "DOOR HARDWARE,"

Set: 12.0 should read as below:

Set: 12.0

Doors: 1.06

3 Hinge	TA2314 4-1/2" x 4-1/2"	US32D	MK
1 Pull Plate	111x70C	US32D	RO
1 Push Plate	70C	US32D	RO
1 Door Closer	1431 O	EN	SA
1 Kick Plate	K1050 10" x 2" LDW 4BE CSK	US32D	RO
1 Wall Stop	409	US32D	RO
3 Silencer	608		RO

END OF ARCHITECTURAL ADDENDUM



TECHNOLOGY ITEMS FOR ADDENDUM NO. 1

NOTICE TO PROPOSERS:

- A. This Addendum shall be considered part of the contract documents for the above-mentioned project as though it had been issued at the same time and incorporated integrally therewith. Where provisions of the following supplementary data differ from those of the original contract documents, this Addendum shall govern and take precedence.
- B. Proposers are hereby notified that they shall make any necessary adjustments in their estimate on account of this Addendum. It will be construed that each Proposer's proposal is submitted with full knowledge of all modifications and supplemental data specified therein. Acknowledge receipt of this addendum in the space provided on the proposal form. Failure to do so may subject Proposer to disqualification.

REFERENCE IS MADE TO THE DRAWINGS AND THE PROJECT MANUAL AS NOTED:

DRAWINGS:

AD No 1, Tech. Item 1: To the Drawings, Sheet TG1.2, "Responsibility Schedule",

- 1) Add to the Responsibility Schedule under "SECTION" "27 4000", under the row heading "SOUND AND PROGRAM SYSTEM EXENTION" and in the row sub-heading corresponding to "CEILING SPEAKERS/HORNS" the wording "TIE INTO EXISTING SYSTEM" into the "NOTES" column. Thus instructing the contractor to tie the paging horns shown on the T-Series floor plans to the existing paging system adding the field house building to the existing school's paging system.

END OF ADDENDUM